



Certificate of Compliance

Certificate: 1133914 (LR 112901)

Master Contract: 157406

Project: 2463002

Date Issued: October 11, 2011

Issued to: Karl Dungs Inc.

3890 Pheasant Ridge Dr NE, Ste 150
Blaine, MN 55449
USA
Attention: Kevin Carlisle

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



Valdis Udris

Issued by: Valdis Udris

PRODUCTS

CLASS 3371 03 - VALVES (GAS) - Automatic - For Gas Appliances

CLASS 3371 83 - VALVES (GAS) - Automatic-For Gas Appliances-Certified to U.S. Standards

Model Number	Capacity	Size	PSIG
--------------	----------	------	------

·For Use With Natural, Liquefied Petroleum or Propane Gas

Automatic Valves

Trade Name: DUNGS

MV-D 505/60(2,4)	300,000	1/2	5
MV-D 507/60(2,4)	500,000	3/4	5
MV-D 510/60(2,4)	800,000	1	5
MV-D 512/60(2,4)	1,400,000	1-1/4	5
MV-D 515/60(2,4)	1,600,000	1-1/2	5



Certificate: 1133914 (LR 112901)

Master Contract: 157406

Project: 2463002

Date Issued: October 11, 2011

MV-D 520/60(2,4)	2,500,000	2	5
MV-D 525/60(2,4)	4,000,000	2-1/2	5
MV-D 530/60(2,4)	6,500,000	3	5
MV 505/60(2,4)	300,000	1/2	5
MV 507/60(2,4)	500,000	3/4	5
MV 510/60(2,4)	800,000	1	5
MV 512/60(2,4)	1,400,000	1-1/4	5
MV 515/60(2,4)	1,600,000	1-1/2	5
MV 520/60(2,4)	2,500,000	2	5
MV 525/60(2,4)	4,000,000	2-1/2	5
MV 530/60(2,4)	6,500,000	3	5
MV-DLE 205/6	300,000	1/2	2
MV-DLE 207/6	500,000	3/4	2
MV-DLE 210/6	800,000	1	2
MV-DLE 212/6	1,400,000	1-1/4	2
MV-DLE 215/6	1,600,000	1-1/2	2
MV-DLE 220/6	2,500,000	2	2
MV-DLE 225/6	4,000,000	2-1/2	2
MV-DLE 230/6	6,500,000	3	2

The MV-D(LE) Series valves are certified for operation at a temperature of minus 20°F to plus 125°F.

APPLICABLE REQUIREMENTS

ANSI Z21.21-2005·CSA 6.5-2005

Automatic Valves for Gas Appliances

Z21.21a-2010·CSA 6.5a-2010