

PUMP SECTION

Centrifugal Pumps, Type RC05 and RC06 - Close Coupled, End Suction



General Service Pumps Flows to 120 GPM, 60 PSI Horizontal 56J Frame

FEATURES

- 1) CASE Discharge can be located in any of four (4) positions. Back pull-out design eliminates the need to disturb piping. Material of construction, class 30 cast
- 2) IMPELLER Advanced impeller design for maximum hydraulic efficiency, dynamically balanced for vibration free operation.
- 3) MECHANICAL SEAL Buna N shaft seal rated for

250 degrees Fahrenheit and pressures up to 175 PSI. ceramic seat and carbon seal face for long trouble free service. Alternative seals are available to suit temperatures and liquid.

4) SHAFT/MOTOR - One piece stainless steel threaded shaft and ball bearing construction in all open drip proof enclosures. Shaft and mounting flange comply with Nema standards allowing interchangeability.

MATERIALS OF CONSTRUCTION 8 MATERIAL **OPTION** 2 CLASS 30 C.I. BRONZE 3 **BRONZE** CLASS 30 C.I. **BRONZE CAST IRON BUNA N EPT/VITON** 9 **BUNA N EPT/VITON** STEEL STEEL **BRONZE** NEMA (ODP) TEFC/XPROOF SST **BRASS** SST MONEL STEEL 6 3450 250 DEGREES FAHRENHEIT 300° F = EPT. 400° F = VITON 125 LB. FLANGES 265 PSI

10 WASHER

DESCRIPTION

CASE

ADAPTER

IMPELLER

PIPE PLUG

CAP SCREW

O-RING

BOLTS

MOTOR

BASE

MECH. SEAL

MAXIMUM OPERATING CONDITIONS

Based on Std. Construction & Pumping Clear Water

RPM -

HORSEPOWER -

STD. SEAL TEMP. -OPT. SEAL TEMP.

MODEL R5, R6 -MAX. WORKING PRESS. - 175 PSI

HYDROSTATIC

ITEM

1

2

3

4

5 6.7


8

9


11

12

TEST PRESSURE -



DIMENSIONS



TYPICAL SPECIFICATIONS

- Furnish and install pumps with capacities as shown on plans. Pumps shall be close coupled, single-stage, vertically-spiit case design, capable of being serviced without disturbing piping. Pump volute shall be Class 30 cast iron and impeller shall be brass enclosed type, dynamically balanced.
- Seal shaft shall be of rotary type and suitable for water temperatures up to 250 degrees Fahrenheit.
- Pumps shall be rated for minimum of 175 psi working pressure. Casings shall have vent and drain ports at top and bottom.
- Motor shall meet NEMA specifications and shall be of the size, voltage and enclosure called for on the plans. It shall have heavy-duty
 sealed ball bearings, stainless steel shaft, adequate for the maximum load for which the motor is designed. Each pump shall be factory
 tested. It shall then be thoroughly deaned and painted with at least one coat of high-grade lacquer prior to shipment.
- Each pump shall be checked by contractor and regulated for proper pressure, voltage and amperage draw. Data shall be noted on a tag
 or label and fastened to pump for reference. Pumps shall be Series RC05 or RC06 as manufactured by MEPCO.

